



GENERAL NOTES:

1. REFERENCE DETAILS, 3000, 3010, AND 3020, FOR BEDDING AND BACKFILL REQUIREMENTS.
2. MAINTAIN 18" MINIMUM CLEARANCE FROM OUTER MOST EDGE OF TRENCH TO BACK OF CURB. THE REQUIREMENT APPLIES TO BOTH FUTURE AND EXISTING STREETS.

**WATER MAIN LOCATION  
IN STREET RIGHT OF WAY**

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p><i>David Powell, PE</i> 5-26-16</p> <p>CITY ENGINEER      DATE</p>	<p>CITY OF WICHITA FALLS, TX ENGINEERING DIVISION</p> <p>MAY 2016</p>	<p>WATER MAIN LOCATION IN STREET RIGHT OF WAY</p> <p>DETAIL NO.    4000</p>
---	---	---