


**PLAN**



**SECTION A-A**

**GENERAL NOTES:**

1. SLOPE OF SIDEWALK AT DRIVE APPROACHES MUST COMPLY WITH ADA REQUIREMENTS (1" PER FOOT MAXIMUM).
2. SEE DRIVE APPROACHES, ITEM 305.2 OF THE STANDARD SPECIFICATIONS.
3. ALL CONCRETE SHALL BE CLASS "C" (COMPRESSIVE STRENGTH OF 3600 PSI @ 28 DAYS).
4. SAND SHALL NOT BE ACCEPTED AS COMPACTED SUBGRADE. SAND WILL BE ALLOWED FOR LEVEL-UP ONLY.
5. ALL STEEL SHALL HAVE A 2" MINIMUM COVER.
6. REBAR SHALL STOP 2" PRIOR TO EDGE OF EXISTING STREET.
7. ANY UTILITY BOXES OR MANHOLES WITHIN THE APPROACH MUST BE ADJUSTED BY THE CITY UTILITY DEPARTMENT, OR OWNER OF UTILITY, TO BE FLUSH WITH FINISH GRADE, OR RELOCATED OUT OF THE APPROACH TO THE PROPER GRADE. ALL ADJUSTMENT COST WILL BE THE RESPONSIBILITY OF THE CONTRACTOR, OR THE OWNER INSTALLING THE APPROACH.

**RESIDENTIAL DRIVE APPROACH  
CONCRETE STREET**

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p>CITY ENGINEER</p>	<p>CITY OF WICHITA FALLS, TX ENGINEERING DIVISION</p> <p>AUGUST 2015</p>	<p>RESIDENTIAL DRIVE APPROACH CONCRETE STREET</p>
<p>DATE</p> <p>8-3-15</p>		<p>DETAIL NO. 2140</p>