



GENERAL NOTES:

1. CONCRETE SHALL BE CLASS "C" 3600 PSI.
2. FRAME SHALL BE THOROUGHLY GROUTED IN PLACE PRIOR TO PLACING CONCRETE APRON.
3. FOR REPAIR WORK REUSE EXISTING MANHOLE FRAME AND COVER WHEN ADJUSTING EXISTING COVER TO GRADE.
4. EXISTING MANHOLE FRAME AND COVER DAMAGED BY CONSTRUCTION SHALL BE REPLACED AT CONTRACTORS EXPENSE WITH PROPER FRAME AND COVER OF SAME SIZE AND TYPE.

SECTION A-A

CONCRETE APRON
ASPHALT STREETS / ALLEYS ONLY

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p>CITY ENGINEER</p>	<p>CITY OF WICHITA FALLS, TX ENGINEERING DIVISION</p> <p>MARCH 2016</p>	<p>CONCRETE APRON ASPHALT STREETS / ALLEYS ONLY</p> <p>DETAIL NO. 5035</p>
<p>6-10-16 DATE</p>		