



GENERAL NOTES:

1. DETAILS AS TO PAVEMENT SLAB WIDTH, THICKNESS, AND CROWN CROSS-SLOPE SHALL BE AS SHOWN ELSEWHERE ON THE PLANS.
2. REINFORCING FOR THE ANCHOR LUGS SHALL BE STEEL CONFORMING TO ASTM DESIGNATION A615, GRADE 60 OR A-616, GRADE 60. ALL STEEL IN LUGS AND SUPPORT SLAB SHALL BE #5 BARS.
3. SAWCUT TRANSVERSE CONTRACTION JOINTS WILL NOT BE PERMITTED WITHIN THE LIMITS OF THE ANCHOR LUGS WITHOUT THE APPROVAL OF THE ENGINEER.
4. SEE CONCRETE PAVEMENT SECTION DETAIL 2000 AND EXPANSION JOINT DETAIL 2051 FOR ADDITIONAL INFORMATION.

**TERMINAL ANCHOR WITH EXPANSION JOINT
FOR
CONCRETE PAVEMENT**

NOT TO SCALE

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p><i>D. Paul, P.E.</i> 9-27-17</p> <p>CITY ENGINEER DATE</p>	<p>CITY OF WICHITA FALLS, TX ENGINEERING DIVISION</p> <p>SEPTEMBER 2017</p>	<p>TERMINAL ANCHOR WITH EXPANSION JOINT FOR CONCRETE PAVEMENT</p> <hr/> <p>DETAIL NO. 2071</p>
--	---	---