



GENERAL NOTES:

1. PRIVATE SEWER SERVICES ARE TO BE CONSTRUCTED TO CLEAR EXISTING AND PROPOSED UTILITIES, SUCH AS STORM SEWER MAINS, WATER MAINS, OTHER UTILITIES, ETC. THE WASTEWATER LATERAL SHALL HAVE A MINIMUM COVER OF 4'-0" BELOW THE PROPOSED CURB GRADE AT THE PROPERTY LINE, DETERMINED FROM PAVING GRADE, OR AS REQUIRED TO MAINTAIN A MINIMUM OF 1.00% GRADE, OR AS DIRECTED BY THE CITY ENGINEER.
2. MARK END LOCATION WITH 2" X 2" X 36" WITH WOODEN STAKE, PAINTED GREEN, DRIVEN FIRMLY IN THE GROUND.

SERVICE PIPE CONNECTION
MAIN IN STREET

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p>  <p>CITY ENGINEER</p>	<p>10-10-17</p> <p>DATE</p>	<p>CITY OF WICHITA FALLS, TX</p> <p>ENGINEERING DIVISION</p> <p>OCTOBER 2017</p>	<p>SERVICE PIPE CONNECTION</p> <p>MAIN IN STREET</p>
			<p>DETAIL NO. 5090</p>