



GENERAL NOTES:

1. SEE ALLEY PAVING ITEM 303.6 OF THE STANDARD SPECIFICATIONS.
2. SUB GRADE PREPARATION SHALL CONSIST OF 6" LIME STABILIZATION IN ACCORDANCE WITH ITEM 301.2 OF THE STANDARD SPECIFICATIONS, APPLIED AT A RATE OF 30 LBS./ PER SQ.YD., COMPACTED TO 95% ASTM D-698.
3. 6" INCHES OF FLEXIBLE BASE MEETING THE REQUIREMENTS OF ITEM 301.5 OF THE STANDARD SPECIFICATIONS, MAY BE SUBSTITUTED FOR LIME STABILIZED SUBGRADE.
4. ALL CONCRETE SHALL BE CLASS "C" (COMPRESSIVE STRENGTH OF 3600 PSI @ 28 DAYS).
5. ALL EXPOSED CONCRETE SURFACES SHALL BE CURED IN ACCORDANCE WITH ITEM 303.5.7 OF THE STANDARD SPECIFICATIONS.
6. EXPANSION JOINTS SHALL BE PLACED AT EACH END OF THE ALLEY AND AT THE MIDPOINT OF THE ALLEY, WITH MAX. SPACING OF 600'.
7. BACKFILL ADJACENT TO CONCRETE EDGES TO A MINIMUM OF 90% STANDARD PROCTOR (ASTM D-698) IN 6" INCH LIFTS.
8. CONSTRUCT SAWED CONTRACTION JOINTS AT 15' INTERVALS.

PAVEMENT SECTION
ALLEY

NOT TO SCALE

DISCLAIMER: This standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p>CITY ENGINEER</p>	<p>CITY OF WICHITA FALLS, TX ENGINEERING DIVISION</p> <p>JANUARY 2015</p>	<p>PAVEMENT SECTION ALLEY</p>
<p>12-16-14 DATE</p>		<p>DETAIL NO. 2040</p>