



GENERAL NOTES:

1. DOWEL REINFORCEMENT 6" INTO EXISTING CURB AND GUTTER.
2. CONSTRUCT 1/2" EXPANSION JOINTS AT 60' ON CENTER AND CONTRACTION JOINTS AT 15' ON CENTER.
3. SEE CONCRETE CURB & GUTTER, ITEM 305.1 OF THE STANDARD SPECIFICATIONS.
4. ALL CONCRETE SHALL BE CLASS "C" (COMPRESSIVE STRENGTH OF 3600 PSI @ 28 DAYS).
5. SAND WILL NOT BE ACCEPTED AS COMPACTED SUBGRADE. SAND WILL BE ALLOWED FOR LEVEL-UP ONLY. (2" MAX.).
6. MATCH PAVEMENT THICKNESS WHEN PLACED MONOLITHIC WITH CONCRETE PAVEMENT.
7. PROVIDE 1" GUTTER DEPRESSION.

6" CURB AND GUTTER

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats or damages resulting from its use.

APPROVED	CITY OF WICHITA FALLS, TX ENGINEERING DIVISION JANUARY 2015	6" CURB AND GUTTER
 12-16-14 CITY ENGINEER DATE		DETAIL NO. 2120