



GENERAL NOTES:

1. DOWELLED ON CURB SHALL NOT BE CONSTRUCTED EXCEPT TO COMPLETE A BLOCK WITH EXISTING DOWELLED ON CURB OR TO REPLACE EXISTING DAMAGED DOWELLED ON CURB.
2. SEE CONCRETE CURB & GUTTER, ITEM 305.1 OF THE STANDARD SPECIFICATIONS.
4. ALL CONCRETE SHALL BE CLASS "C" (COMPRESSIVE STRENGTH OF 3600 PSI @ 28 DAYS).
5. CONTRACTION AND EXPANSION JOINTS SHALL CORRESPOND TO PAVEMENT JOINT LOCATIONS.

DOWELLED ON CURB
(INFILL & REPLACEMENT ONLY)

NOT TO SCALE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.

<p>APPROVED</p> <p><i>D. Paul</i>, P.E. 12-16-14</p> <p>CITY ENGINEER DATE</p>	<p>CITY OF WICHITA FALLS, TX</p> <p>ENGINEERING DIVISION</p> <p>JANUARY 2015</p>	<p>DOWELLED ON CURB</p> <p>(INFILL & REPLACEMENT ONLY)</p> <hr/> <p>DETAIL NO. 2122</p>
----------------------------------------------------------------------------------------	----------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------