



GENERAL NOTES:

1. DOWEL REINFORCEMENT 6" INTO EXISTING CURB AND GUTTER.
2. CONSTRUCT 1/2" EXPANSION JOINTS AT 60' ON CENTER AND CONTRACTION JOINTS AT 15' ON CENTER.
3. SEE CONCRETE CURB & GUTTER, ITEM 305.1 OF THE STANDARD SPECIFICATIONS.
4. ALL CONCRETE SHALL BE CLASS "C" (COMPRESSIVE STRENGTH OF 3600 PSI @ 28 DAYS).
5. SAND WILL NOT BE ACCEPTED AS COMPACTED SUBGRADE. SAND WILL BE ALLOWED FOR LEVEL-UP ONLY, (2" MAX.).
6. MATCH PAVEMENT THICKNESS WHEN PLACED MONOLITHIC WITH CONCRETE PAVEMENT.
7. PROVIDE 1" GUTTER DEPRESSION.

**CURB AND GUTTER
MOUNTABLE**

NOT TO SCALE

APPROVED

Dodwell, P.E. 12-16-14
CITY ENGINEER DATE

CITY OF WICHITA FALLS, TX
ENGINEERING DIVISION

JANUARY 2015

CURB AND GUTTER
MOUNTABLE

DETAIL NO. 2121

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.