



GENERAL NOTES:

1. WIDTH "B" OF SADDLE
 B=6" WHEN D < 24
 B=10" WHEN 24 < D < 42
 B=12" WHEN D > 42
2. FOR "B"=10" OR THICKER, USE 2 LAYERS OF REINF, TURN HORIZ. BARS 90° TO HOOK AROUND VERTS 1-1/2" CLR OF CONCRETE.
3. FORM 3/4" BEVEL ON ALL EXPOSED CORNERS OF SUPPORT.

CONCRETE VALVE SUPPORT

NOT TO SCALE

APPROVED

D. K. ...
 CITY ENGINEER DATE 5-16-16

CITY OF WICHITA FALLS, TX
 ENGINEERING DIVISION

MARCH 2016

CONCRETE VALVE SUPPORT

DETAIL NO. 4045

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.